

ORDINANCE NUMBER: 2021-01
REVISED FIRE PREVENTION CODE
LEMAY FIRE PROTECTION DISTRICT OF ST. LOUIS COUNTY
(ADOPTED: January 19nd, 2021)

AN ORDINANCE REGULATING AND GOVERNING THE PRESCRIBING MINIMUM REQUIREMENTS AND CONTROLS TO SAFEGUARD LIFE, PROPERTY OR PUBLIC WELFARE FROM THE HAZARDS OF FIRE AND EXPLOSION; KNOWN AS THE FIRE PREVENTION CODE: PROVIDING FOR THE ISSUANCE OF PERMITS, COLLECTION OF FEES, MAKING OF INSPECTIONS, PROVIDING PENALTIES FOR THE VIOLATIONS THEREOF:

BE IT ORDAINED BY THE BOARD OF DIRECTORS OF THE LEMAY FIRE PROTECTION DISTRICT OF ST. LOUIS COUNTY, MISSOURI AS FOLLOWS:

SECTION 1. INCONSISTENT ORDINANCES REPEALED.

Ordinance numbers 94-1 & 94-2 of the Lemay Fire Protection District of St. Louis County, Missouri, and all other Ordinances or parts of Ordinances in conflict herewith are hereby repealed.

SECTION 2. ADOPTION OF FIRE PREVENTION CODE.

That a certain document, three (3) copies of which are on file in the office of the fire code official of the Lemay Fire Protection District of St. Louis County, Missouri, being marked and designated as "ICC[©], International Fire Code", 2015 Edition as published by the International Code Council, Inc., together with the standards which are referenced in Chapter 80, Appendix B – "Fire Flow Requirements for Buildings", and Appendix D – "Fire Apparatus Access Roads", be and is hereby adopted as the Fire Prevention Code of the Lemay Fire Protection District of St. Louis County, Missouri, for the control of buildings and structures as herein provided; and each and all of the regulations, provisions, penalties, conditions, and terms of the "ICC[©], International Fire Code", 2015 Edition, are hereby referred to, adopted and made a part hereof, as if more fully set out in this Ordinance together with the additions, insertions, deletions and changes prescribed in Section 4 of this Ordinance, all of which shall be referred to as the "Fire Prevention Code" or the "Fire Code." The ICC[©] International Fire Code, 2015 Edition may be viewed at "http://codes.iccsafe.org/app/book/toc/2015/I-codes/2015_IFC_HTML/index.html" or purchased from the International Code Council, 500 New Jersey Avenue, NW, 6th Floor, Washington, DC 20001 or by calling (800) 786-4452.

SECTION 3. JURISDICTIONAL TITLES.

100.1 Wherever "name of jurisdiction" appears in the code it shall read the Lemay Fire Protection District of St. Louis County, Missouri.

100.2 Wherever "jurisdiction" or "District" appears in the code it is defined as the "Authority Having Jurisdiction" which for this ordinance is Lemay Fire Protection District of St. Louis County Missouri.

100.3 Wherever "Code Official", "Building Official" or "Fire Code Official" may appear it is defined as the Fire Marshal, Fire Inspector or his duly authorized representative of the Lemay Fire Protection District of St. Louis County, Missouri.

SECTION 4. - ADDITIONS, INSERTIONS AND CHANGES TO THE ICC®, INTERNATIONAL FIRE CODE, 2015 EDITION

CHAPTER 1 – SCOPE AND ADMINISTRATION

SECTION 104.12. Add a new section. Insert:

104.12 Rule - making authority: The fire code official shall have authority as necessary in the interest of public health, safety and general welfare, to adopt and promulgate rules and regulations to interpret and implement the provisions of this code to secure the intent thereof and to designate requirements applicable because of local climatic or other conditions. Such rules shall not have the effect of waiving structural or fire performance requirements specifically provided for in this code or of violating accepted engineering practice involving public safety.

SECTION 105.3.3. Delete existing text. Insert:

105.3.3 Occupancy prohibited before approval. Except as specifically provided for temporary occupancy in the building, a building, structure or portion thereof, shall not be used or occupied in whole or in part until all fire protection devices, life safety and equipment protecting the building, structure or portion to be occupied, have been tested and approved by the fire code official charged with enforcing this fire code. All portions of the means of egress for the building, structure or portion to be occupied shall be unobstructed and available for immediate use.

SECTION 105.6.49. Add a new section. Insert:

105.6.49 Helicopter hoisting and lowering operations. Approval is required for helicopter hoisting and lowering operations in accordance with the following.

The helicopter service or the contractor in charge of a helicopter hoisting or lowering operations shall demonstrate financial responsibility of liability for damages arising from the hoisting or lowering operation by providing the fire code official with proof of insurance or other appropriate financial responsibility. Forty-eight (48) hours' notice shall be provided before the hoisting or lowering operation is to begin. Notification shall be made to other jurisdictional agencies as may be required.

SECTION 105.6.49.1 (page 9). Add a new section. Insert:

105.6.49.1 Safety precautions. During all helicopter lifting or lowering operations, the following safety precautions shall be followed:

1. The fire and police departments shall approve landing sites, if landings are necessary.
2. All materials or equipment to be lifted shall be brought as close as possible to the building or structure site by road vehicles.
3. The helicopter shall not carry equipment or materials lifted to or lowered from a building or structure over pedestrians, spectators, other buildings or vehicles.

4. When the operation involves setting or removing equipment or materials from or on an occupied building, the top 2 floors of the building shall not be occupied by anyone, other than individuals directly involved with the operation while the hoisting or lifting operation is in progress.
5. All flammable or combustible liquids brought to the site for refueling helicopters shall be stored, used and dispensed in accordance with Chapters 11 and 34 of this fire code.
6. A fire department safety officer, or fire department safety team, must be present on the sited during all helicopter lifting or lowering operations. The safety officer, or safety team, shall terminate the lift if weather conditions or other variables make the operation unsafe. The safety officer, or safety team, shall be provided radio communications with the helicopter pilot in the event safety conditions mandate evasive action.

SECTION 108.1 through 108.3. Delete in its entirety. Insert:

108.1 Appeals. An owner, lessee, agent, operator or occupant aggrieved by an order pursuant to this ordinance, may file an appeal to the Board of Directors within ten (10) days from the service of any order, and the Board of Directors shall fix a time and place not less than five (5) days or more than twenty (20) days thereafter when and where such an appeal may be heard by it. Such appeal shall stay the execution of such order until it has been heard and reviewed, vacated or confirmed by the Board. In computing the number of days, Saturdays, Sundays and legal holidays shall be excluded.

The Board of Directors shall, at such hearings, affirm, modify, revoke or vacate such order. In conducting and holding the hearing, the Board of Directors shall follow the procedures set forth in §536 RSMO. for "contested" matters. Unless revoked or vacated, such order shall then be complied with.

Nothing herein contained shall be deemed to deny the right of any person, firm, corporation, partnership or voluntary association to appeal from an order of a decision of the Board of Directors to a court of competent jurisdiction. Appeals from final decisions of the Board shall be to the appropriate Circuit Court, pursuant to the provisions of §536.100 RSMO. Such appeals shall stay the execution of such order until it has been heard and reviewed, vacated or confirmed by the Court.

SECTION 109.4 and 109.4.1. Delete in its entirety. Insert:

109.4 Violation, penalties. Any person, firm or corporation who shall violate any provision of this Ordinance, or who shall fail to comply with any of the requirements thereof, or who shall erect, construct, alter or repair a structure in violation of an approved plan or directive of the fire code official, or of a permit or certificate issued under the provisions of this Ordinance, or shall start any work requiring a permit without first obtaining a permit therefore, or who shall continue any work in or about a structure after having been served a stop-work order, except for such work which that person, firm or corporation has been directed to perform to remove a violation or unsafe condition, or any owner or tenant of a building, or premises or any other person who commits, takes part or assists in any violation of this Fire Code or who maintains any building or premises in which such may cause to be instituted in the name of the District, a civil action for injunction or other appropriate relief to secure a compliance with the provisions of this Fire Code. Injunctive or other appropriate relief shall not be denied on the grounds that an adequate remedy at law exists through the imposition of criminal sanctions.

SECTION 109.5. Add a new section. Insert:

109.5 Unlawful continuance. Any person who shall continue any work in or about the structure after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe conditions, shall be liable to penalties as specified in Section 109.4 of this Ordinance.

SECTION 109.6. Add a new section. Insert:

109.6 Civil action. Notwithstanding the provisions hereof, the fire code official, with the approval of the Board of Directors, may cause to be instituted in the name of the District, a civil action for injunction or other appropriate relief to secure a compliance with the provisions of this Fire Code as adopted by this ordinance. Injunctive or other appropriate relief shall not be denied on the grounds that an adequate remedy at law exists through the imposition of criminal sanctions.

SECTION 111.4. Delete in its entirety. Insert:

111.4 Failure to comply. Any person who shall continue any work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be in violation of Section 109.4 and 109.5 of this ordinance.

CHAPTER 2 – DEFINITIONS

SECTION 202 - insert new definitions:

BEDROOM – SLEEPING ROOM. Any space in the conditioned area of a dwelling unit or accessory structure which is 70 square feet and greater in size and which is located along an exterior wall, but not including the following: hall; bathroom; kitchen; living room (maximum of one per dwelling unit); dining room (in proximity to kitchen, maximum of one per dwelling unit); family room (maximum of one per dwelling unit), laundry room, closet/dressing room opening off of a bedroom.

The fire code official may grant exceptions if a room, by its design, cannot function as a bedroom. Sewing rooms, dens, studios, lofts, game rooms, and any other conditioned room along an exterior wall which is 70 square feet or greater in size will be considered to be bedrooms unless the room is specifically exempted. If a home office, library or similar room is proposed, it may be exempted from being considered a bedroom if there is no closet and at least one of the following is present:

1. Permanently built-in bookcases, desks and other feature that encumber the room in such a way that it cannot be used as a bedroom;
2. A minimum 4 foot opening, without doors, into another room; or
3. A half wall (4 foot maximum height) between the room and another room. A detached building which contains only a half bath will not routinely be considered as having a bedroom unless it is specifically identified and permitted as a guest house.

When an exception is made per the above, it shall be documented in Permits Application Documents and Submitted Plans in the comments section so that all staff are aware of the determination.

A conditional statement may be required to be signed by the property owner if the permit is for an outbuilding which has been determined to be a use other than a bedroom or other living space. This statement may be recorded as necessary to inform future property owners of restrictions on use of the building.

Child care facility. A child care facility which accommodates more than ten children 2 ½ years of age or less for any length of time.

Family day care home: A family home occupied as a permanent residence by the daycare provider, in which family like care is given for more than four (4) children, but not more than ten (10) children, not related to the daycare provider, for any part of the twenty-four (24) hour day.

MOBILE FOOD UNIT: An enclosed vehicle-mounted food service establishment designated to be readily movable from which food is composed, compounded, processed or prepared and from which food is vended, sold or given away.

CHAPTER 3 – GENERAL REQUIREMENTS

SECTION 307.1.1. Delete in its entirety. Insert:

307.1.1 Prohibited open burning. Open burning that will be offensive or objectionable because of smoke or odor emissions when atmospheric conditions or local circumstances make such fires hazardous shall be prohibited. The fire code official is authorized to order the extinguishment by the permit holder or the fire district of open burning which creates or adds to a hazardous or objectionable situation.

SECTION 307.2. Delete in its entirety. Insert:

307.2 Permit required. A permit shall be obtained from the fire code official in accordance with Section 105.6 prior to kindling a fire for recognized silvicultural or range or wildlife management practices, prevention or control of disease or pests, or a bonfire. Application for such approval shall only be presented by and permits issued to the owner of the land upon which the fire is to be kindled.

Exception: Permanently installed fire pits, no larger than three (3) feet by three (3) and portable outdoor fireplaces used at one- and two- family dwellings.

SECTION 307.4.1 and 307.4.2. Delete in its entirety. Insert:

307.4.1 Bonfires and Recreational fires. Bonfires and recreational fires shall not be conducted within 25 feet (7620 mm) of a structure or combustible material. Conditions which could cause a fire to spread within 25 feet (7620 mm) of a structure shall be eliminated prior to ignition. The maximum pile size is 3 feet (914mm) or less in length or width and 3 feet (914mm) or less in height.

SECTION 307.4.3. Delete in its entirety and exception. Insert:

307.4.3 Portable outdoor fireplaces. Portable outdoor fireplaces shall be used in accordance with the manufacturer’s instructions and shall not be operated within 15 feet (3048 mm) of a structure or combustible material. Portable outdoor fireplaces shall not be used for burning trash, rubbish or food waste.

SECTION 308.1.6.3. Delete in its entirety. Insert:

308.1.6.3 Sky lanterns. No person shall release or cause to be released a sky lantern or other type of unmanned device that relies on an open flame to heat the air inside the device in order to make the device airborne.

CHAPTER 5 – FIRE SERVICE FEATURES

SECTION 505.1. Delete in its entirety. Insert:

505.1 Address identification. New and existing buildings shall have approved address identification. The address identification shall be legible and placed in a position that is visible from the street or road fronting the property. Address identification characters shall contrast with their background. Address identification on glass shall be white in color. Building address numbers shall be Arabic numbers format. Suite or sub-address identification shall be Arabic number or alphabetical letters. Numbers shall not be spelled out. Each character shall be not less than 6 inches (152 mm) high with a minimum stroke width of 1/2 inch (12.7 mm). Where required by the fire code official, address identification shall be provided in additional approved locations to facilitate emergency response. Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure. Address identification shall be maintained.

SECTION 505.1.1. Add a new section. Insert:

505.1.1 Buildings with single address identification. New and existing buildings that have only one address with no suites or sub-address identification shall have address identification on all four sides of the building.

SECTION 505.1.2. Add a new section. Insert:

505.1.2 Buildings with multiple address identification. New and existing buildings that have multiple addresses, suites, apartments or sub-address identification shall have main building address identification on all four sides of the building. All exterior doors, man doors and overhead doors, shall have address identification on the exterior side or each door which accesses that suite, tenant space or sub-address. Address identification shall include building address identification and suite or sub-address identification. Each character shall be not less than 4 inches (102 mm) high with a minimum stroke width of 1/2 inch (12.7 mm). Building address numbers shall be Arabic numbers format. Suite or sub-address identification shall be Arabic number or alphabetical letters. All numbers shall not be spelled out. Address identification characters shall contrast with their background. Address identification on glass shall be white in color. All interior doors with access from a main corridor or hallway shall have suite, apartment or sub-address identification on all

doors which access that space. The interior door access identification shall meet a building standard either on the actual door or next to the door.

SECTION 507.5.1.1. Delete in its entirety. Insert:

507.5.1.1 Hydrant for fire department connections. Buildings equipped with sprinkler systems installed in accordance with Section 903 and standpipe systems installed in accordance with Section 905 shall have a fire hydrant within 100 feet (30 480 mm) of the fire department connections.

Exception: The distance shall be permitted to exceed 100 feet (30 480 mm) where approved by the fire code official.

SECTION 507.5.5.1. Add a new section. Insert:

507.5.5.1 No parking area: When fire department connections are located in an area where vehicles may be parked or standing, said parking or standing shall be restricted for ten (10) feet in each direction from the fire department connection. No parking identification area shall be approved by the fire code official.

SECTION 507.5.7. Add a new section. Insert:

507.5.7 Color coding of public fire hydrants. All public fire hydrant barrels are to be painted yellow. All fire hydrant bonnets shall be painted as follows:

<u>COLOR</u>	<u>WATER MAIN SIZE</u>
Green	Twelve (12) inch and larger
Orange	Eight (8) and ten (10) inch
Red	Six (6) inch and smaller

SECTION 507.5.8. Add a new section. Insert:

507.5.8 Color coding of private fire hydrants: All private fire hydrants shall be painted yellow, including the bonnet.

SECTION 511.1. Add a new section. Insert:

511.1 High-rise buildings. In addition to other requirements in this code, new and existing high-rise buildings shall conform to Section 511.1.1 through 511.1.2.

SECTION 511.1.1. Add a new section. Insert:

511.1.1 Firefighter assist plans. An approved pictographic display (sign, drawing or wall marking) shall be posted within all enclosed stairways at each floor landing in all new and existing high-rise buildings. Individual displays, or signs, shall show the floor level number where the graphic is displayed, the configuration of exit corridors, including all door openings, exit stairways, elevators, exterior building walls, fire alarm pull stations, fire hoses and sprinkler valves. The display shall be located approximately 5 feet above the floor landing in a position that is readily visible when the door is in the open or closed position.

SECTION 511.1.2. Add a new section. Insert:

511.1.2 Exterior floor identification. All new and existing high-rise buildings shall be marked on the exterior with floor level identification dots. Said dots shall not be less than 8 inches in diameter and be of illumination reflective material. Dots shall identify every 5th floor level of the building, in relationship to floor level indicators inside elevator cars. Dots must be visible on all faces or sides of the building. Specific dot locations shall be approved by the fire code official.

CHAPTER 6 – BUILDING SERVICES AND SYSTEMS

SECTION 607.1.1. Add a new section. Insert:

607.1.1 Elevator emergency operations testing: All elevators that are equipped with emergency elevator operations in accordance with ASME A17.1 listed in Chapter 80, shall be tested at least once each year in all phases of emergency functions. An approved elevator service company shall conduct tests.

CHAPTER 9 – FIRE PROTECTION SYSTEMS

SECTION 901.6.2. Delete in its entirety. Insert:

901.6.2 Records. Records of all system inspections, tests and maintenance required by the referenced standards shall be maintained on the premises for a minimum of 3 years or for the required testing frequency if greater than 3 years and shall be made available to the fire code official, not less than quarterly. Accurate logs shall be maintained indicating the number, location and type of device tested. Any defect, modification or repair shall be logged. Additional tag or system inspection record, identifying date, inspector, system pressures and company who inspector is employed shall be attached to each system riser or posted in the immediate area of each system riser. The company conducting the inspection shall have an address and telephone number identified on the tag or system inspection record.

SECTION 901.6.3. Add a new section. Insert:

901.6.3 Annual inspection reporting. All fire protection systems, which require an annual or semi-annual inspection under the respective NFPA Code shall submit such reports within thirty (30) days of the inspection in an Adobe PDF electronic format to the District. This electronic document shall be sent to the District via e-mail to [mailto: jlewe@Lemayfire.ORG](mailto:jlewe@Lemayfire.ORG). The type of fire protection system inspection and address of inspection shall be included in the "Subject" of the e-mail.

SECTION 903.3.5.3. Add a new section. Insert:

903.3.5.3 Water flow tests. Water flow tests for automatic sprinkler systems shall be conducted between the hours of 8:00 a.m. and 4:30 p.m., Monday through Friday. Tests shall be conducted within the last twelve (12) months of submitted construction design documents.

SECTION 903.3.5.4. Add a new section. Insert:

903.5.3.1 Water flow safety factor. A safety factor shall be applied to all flow tests for automatic sprinkler systems. A parallel curve shall be drawn to the actual flow test curve that has been reduced by 20% of the static pressure. An automatic sprinkler system design shall not exceed the 20% curve.

SECTION 903.4.1. Delete in its entirety. Insert:

903.4.1 Monitoring. Alarm, supervisory and trouble signals shall be distinctly different and shall be monitored in accordance with Section 907.6.6 and shall sound an audible signal at a constantly attended location.

Exceptions:

1. Underground key or hub valves in roadway boxes provided by the municipality or public utility are not required to be monitored.
2. Backflow prevention device test valves located in limited area sprinkler system supply piping shall be locked in the open position. In occupancies required to be equipped with a fire alarm system, the backflow preventer valves shall be electrically supervised by a tamper switch installed in accordance with NFPA 72 and separately annunciated.

SECTION 903.7. Add a new Section. Insert:

903.7 Post indicator valves: All automatic sprinkler systems, except limited area sprinkler systems, shall be provided with a post indicator valve that shall control the water supply to all automatic sprinkler systems in that building.

SECTION 904.4.1. Delete in its entirety. Insert:

904.4.1 Acceptance inspection tests. All alternative automatic fire-extinguishing systems shall be tested in accordance with this section. A completed system shall be tested by a discharge of expellant gas through the piping and nozzles. Observations for gas leakage and for continuity of piping with free unobstructed flow shall be made. Observations shall be made of the flow of expellant gas through all nozzles. The identification of devices with proper designations and instructions shall be checked. All dry-chemical and wet-chemical extinguishing systems shall also be tested by a discharge of the extinguishing agent. Discharge quantities shall be in accordance with the manufacturer's installation information and provide on construction documentation. After testing, all piping and nozzles shall be blown clean using compressed air or nitrogen, and the system shall be properly charged and placed in the normal "set" condition.

SECTION 907.1.4. Add a new section. Insert:

907.1.4 Device labeling. All fire alarm and detection devices shall be labeled with a device identification number in an approved manner. Upon an activation signal of a device, the location and the device identification number shall be displayed and correspond with the information on the fire alarm control panel.

SECTION 907.1.5. Add a new section. Insert:

907.1.5 Multiple Fire Alarm Systems. Multiple fire alarm systems within a single protected premise, building or complex are not permitted, unless specifically authorized by the fire code official.

SECTION 907.5.3. Add a new section. Insert:

907.5.3 Fire Sprinkler System Fire Department Connection. An approved exterior audio/visual fire alarm notification device shall be installed above all fire department connections. This device shall activate upon a water flow fire alarm signal only. This device shall be visible from the closest fire apparatus access road and installed at twelve feet above ground level or other approved location.

907.5.3.1 Water Flow Alarm Signage. A permanent sign shall also be installed under the audio/visual fire alarm notification device which states "Water Flow Alarm". This sign shall have red letters on a white reflective background. The letters shall be red in color and be Arabic alphabetical letters. Each character shall be not less than 3 inches (76 mm) high.

SECTION 907.6.3. Modify as follows. Insert:

Exception #1 – Delete in its entirety.

Exception #2 - Fire alarm systems that only include manual fire alarm boxes, water-flow initiating devices and not more than 6 additional alarm-initiating devices.

Exception #3 - Special initiating devices that do not support individual device identification. Such initiating devices shall be approved by fire code official.

SECTION 907.6.6. Delete in its entirety. Insert:

907.6.6 Monitoring. All fire alarm systems shall be monitored by an approved central station as defined in NFPA 72. A UL Certificate (UUFX) or FM Placard, in accordance with the NFPA 72 Chapter 26, shall be issued by the UL Listed or FM approved prime contractor for all newly installed fire alarm systems. This regulation shall apply to all new fire alarm systems. An existing fire alarm system wherein the fire alarm control unit or alarm components are to be replaced shall be considered "new" for the purposes of this section. Central station service in full compliance with NFPA 72 Chapter 26 shall be maintained at the protected property, so long as the fire alarm system. This section shall apply to all required and non-required fire alarm systems that are installed within a building.

Exception. Monitoring by an approved central station is not required for:

1. Single- and multiple-station smoke alarms required by Section 907.2.11.
2. Smoke detectors in Group I-3 occupancies.
3. Automatic sprinkler systems in one- and two-family dwellings.
4. Fire alarm systems monitored by a proprietary monitoring system in accordance with NFPA 72 Chapter 26 for which a UL Certificate (UUKA) or FM or other approved documentation has been issued, as approved by the fire code official

SECTION 912.2.2. Delete in its entirety. Insert:

912.2.2 Fire Department Connection Location Signage. On buildings, the fire department connection shall be indicated by an approved sign mounted on the street front or on the side of the building. Such sign shall have red letters "FDC" not less than 6 inches (152 mm) high and words in red letters not less than 2 inches (51 mm) high or an arrow to indicate the location on a white reflective background. Such signs shall be subject to the approval of the fire code official.

SECTION 912.2.3. Add a new section. Insert:

912.2.3 Fire Department Connection Signage. The fire department connection shall be indicated by an approved sign mounted above its location. Such sign shall have red letters "FDC" not less than 6 inches (152 mm) high and the addresses which the fire department connection serves in red letters not less than 2 inches (51 mm) high on a white reflective background. Such signs shall be subject to the approval of the fire code official.

SECTION 912.2.4. Add a new section. Insert:

912.2.4 Fire Alarm Audio/Visual Device. Please see Section 907.5.4 of this ordinance in regards to water flow alarm notification device above the fire department connection.

SECTION 912.4.4. Add a new Section. Insert:

912.4.4 No parking areas at fire department connections: When fire department connections are located in an area where vehicles may be parked or standing, said parking or standing shall be restricted for ten (10) feet in each direction from the fire department connection.

SECTION 916. Add a new Section. Insert:

SECTION 916 - Fire Hydrants

916.1 New Subdivisions. No person shall commence construction of any new building or structure of any kind in any subdivision within the District, unless such person shall have first submitted to the fire code official a plat of the aforesaid subdivision, indicating the proposed installation of the fire hydrants within such subdivision and receive approval by the fire code official.

916.2 New Structures. No person shall commence construction of any new structure, or building, or addition to any structure or building, within or upon any real property within the District, unless such person shall first have submitted to the fire code official a plat or drawing of the property whereon is located such building, structure or addition, which plat or drawing has indicated thereon the nearest existing fire hydrant. If there is not an existing fire hydrant within such distance as is approved by the fire code official, then also the proposed installation of a new fire hydrant or hydrants, and unless, also, the particular locations proposed for such fire hydrants and the number of fire hydrants to be installed if any, shall be approved by the fire code official.

916.3 Installation of other new fire hydrants. No person shall install or cause to be installed any fire hydrant within the District, unless the location thereof and the design and type of the hydrant, including the threads and outlets thereof, shall first have been approved by the fire code official.

916.4 Use Groups R-3 and R-4. There shall be no more than six (6) dwelling units constructed prior to the installation of a public water system with fire hydrants as set forth herein so as to be accessible for Fire District use in the event of a fire emergency.

916.5 Other Use Groups. In all other Use Groups, public water systems with fire hydrants shall be installed with the commencement of construction.

916.6 Fire hydrant placement. Fire hydrants shall be placed within the guidelines of Section 916.6.1 through 916.6.8.

916.6.1 One- and two-family dwellings developments. In Groups R-3 and R-4 occupancies, single family residential developments, fire hydrant spacing shall not exceed five hundred (500) feet from hydrant to hydrant, or as special site conditions may dictate. The maximum distance from the dead end or any point on street or road frontage to a hydrant is one-hundred-fifty (150) feet. Local conditions may be such that this distance may vary as much as one-hundred (100) feet in either direction.

916.6.1.1 Water supply required. In Use Groups R-3 and R-4 single family developments, when the density is one (1) dwelling unit per ten-thousand (10,000) square feet of developed property or less, and there are five (5) or more dwelling units in a single development.

916.6.2 Other occupancy group developments: In all other Use Groups, fire hydrant spacing shall not exceed three hundred (300) feet from hydrant to hydrant, or as special site conditions may dictate. No part of a building shall be more than three hundred (300) feet from a fire hydrant. Local conditions may be such that the distance between fire hydrants or from a building to a fire hydrant may vary as much as seventy-five (75) to one-hundred (100) feet in either direction, if otherwise approved by the fire code official.

916.6.3 Area to be provided with fire hydrants. Fire hydrants and water mains shall be placed along the full length of the property to be developed that abuts an existing and/or proposed improved public way. Variances may be required by the water agency because of water quality considerations.

916.6.4 Fire hydrant spacing. Spacing of fire hydrants along a public way shall be regulated by the occupancy classification of the development that abuts the existing and/or proposed public way.

916.6.5 Private hydrants: Where a development, other than occupancy group R-3 or R-4, is greater than one-hundred-fifty (150) feet from an existing and/or proposed improved public way, measured along the drivable access, additional private fire hydrants shall be required on said developed property, private streets and/or parking lots, at a spacing between fire hydrants as required by the Use Group as set forth in Section 916.6.1 through and including Section 916.6.4.

916.6.6 No parking area at fire hydrants. Where fire hydrants are required to be installed in areas where vehicles would be parked or standing, said vehicle parking or standing shall be restricted for ten (10) feet in each direction from the fire hydrant.

916.6.7 Unacceptable locations for fire hydrants. Fire hydrants shall not be permitted in the locations indicated in Section 916.6.7.1.

916.6.7.1 Prohibited locations: A fire hydrant shall not be placed at any location where the fire hydrant could be damaged by vehicular traffic.

916.6.8 Relocation of fire hydrants. Relocation of fire hydrants requested or required by a property owner and/or developer shall be relocated as specified by the water agency's policies and procedures and relocation has been approved by the fire code official.

916.7 Fire hydrant installation. All fire hydrants shall be installed in accordance with Sections 916.7.1 through 916.7.3.

916.7.1 Fire hydrant set back distance. All fire hydrants shall be set back from the curb or edge of pavement. The setback shall not exceed twelve (12) feet.

916.7.2 Fire hydrant connection height. Fire hydrants shall be installed no less than twenty-four (24) inches and no more than thirty-six (36) inches above finished grade, measured from the center of the steamer connection.

916.7.3 Fire hydrant type: All fire hydrants shall be approved by the American Water Works Association (AWWA) and/or Missouri American Water Company.

916.8 Obstructions: There shall be no obstructions, plantings, bushes, trees, signs, light standards, etc., within three (3) feet of any fire hydrant in all directions.

916.9 Color coding of public fire hydrants. All public fire hydrant barrels are to be painted yellow. All public fire hydrant bonnets are to be painted as follows:

<u>COLOR</u>	<u>WATER MAIN SIZE</u>
Green	Twelve (12) inch and larger
Orange	Eight (8) and ten (10) inch
Red	Six (6) inch and smaller

916.10 Color coding of private fire hydrants. All private fire hydrants shall be painted yellow, including the bonnet.

916.11 Minimum fire flow - single fire hydrant. The minimum fire flow from a single fire hydrant in any occupancy group shall be fifteen-hundred (1500) gallons per minute at twenty (20) psi residual pressure unless the new hydrant is ordered on a pre-existing main.

916.12 Minimum fire flow - next two fire hydrants. The minimum fire flow from the next two fire hydrants in any occupancy group shall be a cumulative fifteen-hundred (1500) gallons per minute at twenty (20) psi residual pressure.

916.13 Access. The commencement of construction of any such new subdivision, or new building, or structure or addition by any person, within the District, shall be deemed to be the granting of permission by such person for entry upon such property by the Missouri American Water Company, or other water supplier, for the installation of any such aforesaid fire hydrants and the water main leading thereto, and also to the District and to the members or staff and its equipment, for access to such fire hydrant, or hydrants, which may be located upon any such property, for any purpose whatever within the functions of the District, in considerations of issue of building permit.

916.14 Building permits. The fire code official shall not approve, nor issue building permits for, nor permit the construction of any such new subdivision, or new building or structure or addition,

so long as the owner thereof fails to provide for fire hydrants, or to perform any guarantees, or to permit access, according to this section

Exception: On the application of any person, the Board of Directors of the District may grant exception to the requirements of this Section for fire hydrant installations, where such person shall prove to the satisfaction of the Board of Directors that there is no water supply reasonably available for the installation of hydrants.

SECTION 917. Add a new Section. Insert:

Section 917 - Fire Service Mains and Appurtenances

917.1 General. This section covers the application, installation, inspection, and testing for fire service mains and appurtenance and their components for new and existing buildings and structures.

917.2 Where required. An approved Fire Service Mains and Appurtenances shall be installed in accordance with the provisions of this code and NFPA 24. The Fire Service Mains and Appurtenances shall be designed and installed to support the fire flow requirements of the Standpipe System and Automatic Sprinkler Systems of the building or structure being protected.

917.3 Construction documents. Construction documents for Fire Service Mains and Appurtenances shall be of sufficient clarity to indicate the location, nature and extent of the work proposed and show in detail that it will conform to the provisions of this code, the International Building Code, NFPA 24 and relevant laws, ordinances, rules and regulations, as determined by the fire code official. All construction documents shall meet the requirements of Section 107 of the Building Code.

917.3.1 Required. Construction documents shall be drawn to an indicated scale on sheets of uniform size, with a plan of each floor as applicable, and shall include the following items that pertain to the design of the system:

1. Name of owner.
2. Location, including street address.
3. Point of compass.
4. A graphic representation of the scale used on all plans.
5. Name and address of contractor.
6. Size and location of all water supplies.
7. Size and location of standpipe risers, hose outlets, hand hose, monitor nozzles, and related equipment.
8. The following items that pertain to private fire service mains:
 - a) Type of pipe being installed. (Shall meet requirements of NFPA 24)
 - b) Size.
 - c) Length.
 - d) Location.
 - e) Weight.

- f) Material.
 - g) Point of connection to city main.
 - h) Sizes, types, and locations of valves, valve indicators, regulators, meters, and valve pits.
 - i) Depth at which the top of the pipe is laid below grade.
 - j) Method of restraint. (Shall meet requirements of NFPA 24)
9. The following items that pertain to hydrants:
- a) Size and location, including size and number of outlets and whether outlets are to be equipped with independent gate valves.
 - b) Thread size and coupling adapter specifications if different from NFPA 1963
 - c) Whether hose houses and equipment are to be provided, and by whom
 - d) Static and residual hydrants used in flow
 - e) Method of restraint (Shall meet requirements of NFPA 24)
 - f) Meet requirements of Section 916 of this Code.
10. Size, location, and piping arrangement of Fire Department Connections
11. Location and piping arrangement for Post Indicator Valve. All Post Indicator Valves shall be OSHA safety red in color. Post Indicator Valves shall have address identification signs permanently affixed to body of post to identify the address in which the valve serves.

917.3.2 Manufacturer's Installation Instructions. The Construction Documentation submittals shall include the manufacturer's installation instructions for all pipe used or American Water Works Association (AWWA) installation documentation and any specially listed equipment, including descriptions, applications, and limitations for any devices, piping, or fittings.

917.4 Qualified Installer. Installation work shall be performed by fully experienced and responsible persons. The construction application and installation shall be by a Licensed Master Pipe Fitter, Master Plumber or Master Sprinkler Fitter with St. Louis County, Missouri.

917.5 Inspections. The following inspection shall be conducted during the installation of Fire Main Services and Appurtenance:

1. Pipe / trench inspection. This inspection can be conducted while pipe is being installed into trench. No back fill shall be introduced into trench until inspection unless previous approval from fire code official.
2. Proper fill and tamping of fill around pipe. (Per manufacturer's installation instructions or AWWA installation documents. No rocks per NFPA 24.)
3. Thrust block pre-pour inspection. Framed or non-framed.
4. Thrust block pour inspection.
5. Hydrostatic testing. (Per NFPA 24).
6. Flush Inspection. Flush flow shall be through a minimum four inch opening with proper hose or pipe attached. Hose or pipe shall be restrained to prevent injury and or damage. A catch or filter system shall be attached to the end of the hose to prevent debris from causing injury or damage.

7. Additional inspections may be required by fire code official due to project conditions or project requirements.

917.6 Final authority. The authority having jurisdiction shall always be consulted before the installation, upgrading or remodeling of private fire service mains.

CHAPTER 10 – MEANS OF EGRESS

SECTION 1008.3. Modify as follows. Insert:

1008.3 Emergency power for illumination. The power supply for means of egress illumination shall normally be provided by the premises' electrical supply. All circuits which provide power for emergency means of egress shall be identified in each electrical panel.

SECTION 1008.3.3. Modify as follows. Insert:

6. Mechanical rooms, penthouse areas, rooms containing roof access ladders, commercial kitchens, any room or areas of Occupancy Group H, in any room or area that utilizes hazardous materials or hazardous processes.

SECTION 1010.1.4.2.1. Add a new section. Insert:

1010.1.4.2.1 Power-operated sliding door lock. Sliding doors which use a manual lock to prevent the door from opening manually shall have the following:

1. The locking device is readily distinguishable as locked. The locking device shall be able to be unlocked by a quarter turn bold operation without a key or special knowledge.
2. A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED. The sign shall be in letters 1 inch (25 mm) high on a contrasting background.

SECTION 1010.1.9.3. Modify as follows:

Item #2 – Delete in its entirety.

SECTION 1010.1.9.9. Delete in its entirety. Insert:

1010.1.9.9 Electromagnetically locked egress doors. Doors in the means of egress that are not otherwise required to have panic hardware in buildings with an occupancy in Group A, B, E, I-1, I-2, M, R-1 or R-2 and doors to tenant spaces in Group A, B, E, M, I-1, I-2, R-1 or R-2 shall be permitted to be electromagnetically locked if equipped with listed and labeled hardware that incorporates a built-in switch and meet the requirements below:

1. The listed and labeled hardware that is affixed to the door leaf has an obvious method of operation that is readily operated under all lighting conditions.
2. The listed and labeled hardware is capable of being operated with one hand.
3. Operation of the listed and labeled hardware releases to the electromagnetic lock and unlocks the door immediately.
4. Loss of power to the listed and labeled hardware automatically unlocks the door.

5. Where listed and labeled panic or fire exit hardware is required by Section 1010.1.10, operation of the panic or fire exit hardware also releases the electromagnetic lock.
6. The locking system units shall be listed in accordance with UL 294.
7. Activation of the building fire alarm system or building automatic sprinkler system shall release the electromagnetic lock and unlocks the door immediately.

SECTION 1013.1. Modify as follows:

Exception #2 – Delete in its entirety.

SECTION 1013.3. Delete in its entirety. Insert:

1013.3 Illumination. Exit signs shall be electrically powered internally illuminated. All replacement and new exit signs shall be illuminated with Light Emitting Diode (LED) technology. Exit signs that are externally illuminated shall only be installed upon approval of the fire code official. All circuits which provide power for exit signs shall be identified in each electrical panel.

SECTION 1013.5. Delete in its entirety. Insert:

1013.5 Exit signs. Exit signs shall be listed and labeled in accordance with UL 924 and shall be installed in accordance with the manufacturer’s instructions and Section 604. The letters of the exit sign shall be red in color. Exit signs shall be illuminated at all times. The installation of self-luminous and photoluminescent exit signs shall be by the approval of the fire code official.

SECTION 1013.6.. Modify as follows. Insert:

1013.6 Externally illuminated exit signs. When approved by the fire code official; externally illuminated exit signs shall comply with Sections 1013.6.1 through 1013.6.3.

Chapter 11 – CONSTRUCTION REQUIREMENTS FOR EXISTING BUILDINGS

SECTION 1101.5. Add a new section. Insert:

1101.5 Tenant Separation Walls. Nothing in Chapter 11 nor any other part of the International Fire Code shall prevent the fire code official from requiring the installation, maintenance and/or use of tenant separation walls, as defined under 708.1.1 of the International Building Code 2015 Edition as amended by the Lemay Fire Protection District of St. Louis County, during the remodeling, renovation or re-occupancy of an existing building.

CHAPTER 23 - MOTOR FUEL-DISPENSING FACILITIES AND REPAIR GARAGES

SECTION 2304.3.8. Add a new section. Insert:

2304.3.8 Fire suppression system. The dispensing area (pump islands, canopy and adjacent ground area) shall be provided with an approved automatic fire-extinguishing system.

CHAPTER 32 – HIGH PILED COMBUSTIBLE STORAGE

SECTION 3201.3. Delete in its entirety. Insert:

3201.3 Construction documents. At the time of building permit application for new structures designed to accommodate high-piled storage or for requesting a change of occupancy/use, and at the time of application for a storage permit, plans and specifications shall be submitted for review and approval. In addition to the information required by the International Building Code, the storage permit submittal shall include the information specified in this section. Following approval of the plans, a copy of the approved plans shall be maintained on the premises in an approved location. The plans shall include all of the following:

1. Floor plan of the building showing locations and dimensions of high-piled storage areas.
2. Usable storage height for each storage area.
3. Number of tiers within each rack, if applicable.
4. Commodity clearance between top of storage and the sprinkler deflector for each storage arrangement.
5. Aisle dimensions between each storage array.
6. Maximum pile volume for each storage array.
7. Location and classification of commodities in accordance with Section 3203.
8. Location of commodities that are banded or encapsulated.
9. Location of required fire department access doors.
10. Type of fire suppression and fire detection systems.
11. Location of valves controlling the water supply of ceiling and in-rack sprinklers.
12. Type, location and specifications of smoke removal and curtain board systems.
13. Dimension and location of transverse and longitudinal flue spaces.
14. Documentation from table 3206.2 as per the "Commodity Class" versus the "Size of High-Piled Storage Area," in details in reference to all columns in table.
15. Signed and sealed construction document from a Missouri Licensed Professional Engineer specializing in Fire Protection, confirming automatic sprinkler system coverage and protection to the stored commodity classifications and allowable storage heights with the installed automatic sprinkler system and protection provided.
16. Additional information regarding required design features, commodities, storage arrangement and fire protection features within the high-piled storage area shall be provided at the time of permit, when required by the fire code official.

CHAPTER 50 – HAZARDOUS MATERIALS-GENERAL PROVISIONS

SECTION 5003.5.2. Add a new section. Insert:

5003.5.2 Hazard signals required. Any occupancy required by this fire code and/or state law to provide material safety data sheets, shall provide visible markings on the outside of buildings, rooms and containers where hazardous substances are present. These markings shall be in a location approved by the fire code official. These markings shall conform to the NFPA 704 marking system or with other federal laws or regulations, or in the case of containers, may as an option comply with Safety and Health Administration Hazard Communication Rule, 29 CFR 1910.1200(f).

To avoid duplication of markings, marking requirements of the United States Department of Transportation shall satisfy the requirements in regard to motor vehicles, rolling stock and aircraft.

SECTION 5003.5.3. Add a new section. Insert:

5003.5.3 Main entrance. Where required by Section 5003.5, all buildings shall have a placard located on the main entry door a minimum of eighteen (18) inches from the bottom edge of the door. This placard shall have a minimum dimension of five (5) inches. This placard is not required to be lettered or numbered.

SECTION 5003.5.4. Add a new section. Insert:

5003.5.4 Other doors. All other doors shall have a placard with a minimum dimension of ten (10) inches located in an approved location that identifies the worst hazard category of the product(s) in that area. This placard shall be provided with numerals in accordance with Section 5003.5.2.

SECTION 5003.5.5. Add a new section. Insert:

5003.5.5 Signal size. The exterior markings of buildings or site entrances where materials are stored shall have a minimum signal size of 4". All numbers/letters shall be reflective.

CHAPTER 61 – LIQUEFIED PETROLEUM GASES

SECTION 6109.4. Delete in its entirety. Insert:

6109.4 Separation from means of egress. LP-gas containers stored in buildings in accordance with Sections 6109.9 and 6109.11 shall not be located within 20 feet of any exit access doors, exits, stairways or in areas normally used, or intended to be used, as a means of egress.

TABLE 6109.12. Delete in its entirety. Insert:

TABLE 6109.12 SEPARATION FROM EXPOSURES OF LP-GASCONTAINERS AWAITING USE, RESALE OR EXCHANGE STORED OUTSIDE OF BUILDINGS

QUANTITY OF LP-GAS STORED (pounds)	MINIMUM SEPARATION DISTANCE FROM STORED LP-GAS CYLINDERS TO (feet):						
	Nearest important building or group of buildings or line of adjoining property that may be built upon	Line of adjoining property occupied by schools, places of religious worship, hospitals, athletic fields or other points of public gathering; busy thoroughfares; or sidewalks	LP-gas dispensing station	Doorway or opening to a building with two or more means of egress	Doorway or opening to a building with one means of egress	Combustible materials	Motor vehicle fuel dispenser
720 or less	0	0	5	20	20	10	20

721 – 2,500	10	10	10	20	20	10	20
2,501 – 6,000	10	10	10	20	20	10	20
6,001 – 10,000	20	20	20	20	20	10	20
Over 10,000	25	25	25	25	25	10	20

For SI: 1 foot = 304.8 mm, 1 pound = 0.454 kg.

APPENDIX B – FIRE-FLOW REQUIREMENTS FOR BUILDINGS

TABLE B105.2. Delete in its entirety. Insert:

AUTOMATIC SPRINKLER SYSTEM (Design Standard)	MINIMUM FIRE-FLOW (Gallons Per Minute)	FLOW DURATION (Hours)
No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2)
Section 903.3.1.1 of the International Fire Code	50% of the value in Table B105.1(2) ^a	Duration in Table B105.1(2) at the reduced flow rate
Section 903.3.1.2 of the International Fire Code	50% of the value in Table B105.1(2) ^a	Duration in Table B105.1(2) at the reduced flow rate

For SI: 1 gallon per minute = 3.785 L/min.

a. The reduced fire-flow shall be not less than 1,500 gallons per minute.

APPENDIX D – FIRE APPARATUS ACCESS ROADS

SECTION D103.5. Delete in its entirety. Insert:

D103.5 Fire apparatus access road gates. Security gates installed or constructed on a fire apparatus access road shall comply with Section D103.5.1 through D103.5.3. A permit shall be required before the construction or installation of a security gate across a fire apparatus access road.

1. Where a single gate is provided, the gate width shall be not less than 20 feet (6096 mm). Where a fire apparatus road consists of a divided roadway, the gate width shall be not less than 12 feet (3658 mm).
2. Gates shall be of the swinging or sliding type.
3. Construction of gates shall be of materials that allow manual operation by one person.
4. Gate components shall be maintained in an operative condition at all times and replaced or repaired when defective.
5. Electric gates shall be equipped with a means of opening the gate by fire department personnel for emergency access. Emergency opening devices shall be approved by the fire code official.

6. Methods of locking shall be submitted for approval by the fire code official.
7. Electric gate operators, where provided, shall be listed in accordance with UL 325.
8. Gates intended for automatic operation shall be designed, constructed and installed to comply with the requirements of ASTM F 2200.

SECTION D103.5.1. Add a new section. Insert:

D103.5.1 Number of gates. Fire apparatus shall not be required to pass through more than one gate to access, or pass through, any part of a subdivision, development, facility or building.

SECTION D103.5.2. Add a new section. Insert:

D103.5.2 Electrically operated gates. All electrically operated gates shall be installed in accordance with the following requirements:

1. Set back: The gate shall be at least 50 feet back from the edge of the cross street from which the "gated" street is accessed, and shall open the full width of the required pavement, roadway or driveway.
2. Operation: The gate shall be equipped with a "Siren Activated" system, that will automatically open the gate upon approach of emergency vehicles, which have their sirens sounding in the "yelp" mode and equipped with an optical preemption system compatible with the District Opticom™ system that will automatically open the gate upon the approach of an emergency vehicle with the Opticom™ activated. It shall also be equipped with a 'Rapid Entry' key operated switch to open the gate, in addition to the normal 'resident operated mechanism.' The key switch, when activated, shall keep the gate open until fire district personnel reset it after the emergency. The 'Rapid Entry' key operated switch shall be purchased through the Knox Company.
3. Power failure: The gate shall release in the event of a power failure, allowing it to be opened manually;
4. Manual release: Provide a means to manually release the gate, in addition to item 3 above to allow the gate to be opened in the event the switch, motor, or some other component fails; and
5. Approval prior to use: The gate installation shall be inspected, tested and approved by the Fire Code Official prior to the use of the gate.
6. Gates added to existing subdivisions. Prior to approval a signed petition stating: "I agree with a gate being installed at the entrance to all the streets to the subdivision, I understand that when this gate is installed the fire department response can be lengthened by as much as two additional minutes. I further will not hold the fire department responsible for loss of life or property due to the additional response time." Must be signed by 100% of all residents within the subdivision.

SECTION D103.5.3. Add a new section. Insert:

D103.5.3 Manually operated gates. All manually operated gates shall be installed in accordance with the following requirements:

1. Set Back: The gate shall be at least 50 feet back from the edge of the cross street from which the "gated" street is accessed, and shall open the full width of the required pavement, roadway or driveway;

- 2. Lock: If the gate is to be locked, it shall be equipped with a 'Rapid Entry' padlock, The 'Rapid Entry' padlock shall be purchased through the Lemay Fire Protection District. The gate locking mechanism shall be constructed in such a manner as to always allow the gate to open with the activation/removal of the 'Rapid Entry' padlock; and
- 3. Approval Prior to Use: The gate installation shall be inspected, tested and approved by the Fire Code Official prior to the use of the gate.
- 4. Gates added to existing subdivisions: Prior to approval a signed petition stating: "I agree with a gate being installed at the entrance to all the streets to the subdivision, I understand that when this gate is installed the fire department response can be lengthened by as much as two additional minutes. I further will not hold the fire department responsible for loss of life or property due to the additional response time." Must be signed by 100% of all residents within the subdivision.

SECTION D107.1. Delete in its entirety. Insert:

D107.1 One-and two-family dwelling residential developments. Developments of one-or two-family dwellings where the number of dwelling units exceeds 100 shall be provided with separate and approved fire apparatus access roads.

Exceptions:

- 1. Where there are more than 100, but less than 200, dwelling units on a single public or private fire apparatus access road and all dwelling units are equipped throughout with approved automatic residential sprinkler systems in accordance with Section 903.3.1.1 or 903.3.1.3 of the International Fire Code, access from two directions shall not be required.
- 2. The number of dwelling units on a single fire apparatus access road shall not be increased unless fire apparatus access roads will connect with future development, as determined by the fire code official.
- 3. The fire code official shall be permitted to increase the number of dwelling units allowed with a single fire apparatus access road when topography or other approved reasons do not permit an additional access road to be provided.

SECTION 5. SAVINGS CLAUSE.

That nothing in this Ordinance or in the Fire Prevention Code hereby adopted shall be construed to affect any suit or proceeding pending in any Court, or any rights acquired or liability incurred, or any cause or causes of action acquired or existing under any act or Ordinance hereby repealed, as cited in Section 1; nor shall any just or legal right or remedy of any character be lost, impaired or affected by this Ordinance.

SECTION 6. VALIDITY.

If any Section, subsection, provision, sentence, clause or phrase of this Ordinance or of the "ICC© International Fire Code", 2015 Edition, is, for any reason, held to be unconstitutional or invalid, such decision shall not affect the validity of the remaining portions of this Ordinance or of said Fire Prevention Code, and the Lemay Fire Protection District of St. Louis County, Missouri, hereby declares that it would have passed the same, even though such portions so held to unconstitutional had not been included therein.

SECTION 7. VIOLATION, PENALTIES.

Any person, firm or corporation who shall violate any provision of this Ordinance, or who shall fail to comply with any of the requirements thereof, or who shall fail to comply with any order issued pursuant to any Section thereof, shall be guilty of a Class A misdemeanor pursuant to §321.600(12) and §557.021 RSMO and punishable as provided by law. Each day that a violation exists or continues to exist shall be deemed a separate offense.

SECTION 8. EFFECTIVE DATE.

This Ordinance Number **2021-01** having been duly considered and voted upon by the Board of Directors of the Lemay Fire Protection District of St. Louis County, Missouri, was duly enacted as an Ordinance of said Fire Protection District on the **19nd** day of **January, 2021**. The effective date of the Ordinance shall be at **12:01 AM** on the **1st** day of **February, 2021**.

Jerry Schloss, Chairman

David Meyer, Treasurer

Jerry Cox, Secretary